



**SANITARY SEWER OVERFLOW
ANNUAL REPORT**

DATE: 03/12/14

FACILITY NAME: Mount Vernon WWTP

OHIO NPDES PERMIT NO: 4PD00100*LD

PERIOD COVERED BY REPORT: January 1, 2013 - December 31, 2013

CONTACT PERSON

NAME: Judith Scott

TITLE: Administrator, Treatment and Distribution

MAILING ADDRESS:

3 Cougar Drive
Mount Vernon, Ohio 43050

TELEPHONE: 740-393-9502

EMAIL: treatdistadmin@mountvernonohio.org

I CERTIFY UNDER PENALTY OF LAW THAT I HAVE PERSONALLY EXAMINED AND AM FAMILIAR WITH THE INFORMATION IN THIS REPORT AND ALL ATTACHMENTS. BASED ON MY INQUIRY OF THOSE PERSONS IMMEDIATELY RESPONSIBLE FOR OBTAINING THE INFORMATION CONTAINED IN THE REPORT, I BELIEVE THAT THE INFORMATION IS TRUE, ACCURATE, AND COMPLETE.

Judith Scott

Signature of Official

3-13-14

Date

Administrator

Title



Enter narrative analysis of WIB patterns by location, frequency and cause.

Two blockages in the 414 area were unrelated and on different dates.

Two blockages in the 423 area, while on different dates, were likely related due to the close proximity of the homes. Camera investigation of the sewer main did not reveal any structural defects that would have contributed to the problem.

The WIBs in the 404 area were at the same home. This problem has been identified as one associated with extreme weather.