

**SANITARY SEWER OVERFLOW
ANNUAL REPORT**

DATE: 03/19/15

FACILITY NAME: City of Mount Vernon Wastewater Treatment Plant

OHIO NPDES PERMIT NO: 4PD00100*LD

PERIOD COVERED BY REPORT: 1 January 2014 to 31 December 2014

CONTACT PERSON

NAME: Mathias G. Orndorf

TITLE: Interim Administrator, Treatment and Distribution

MAILING ADDRESS:

3 Cougar Drive
Mount Vernon, Ohio 43050

TELEPHONE: 740-393-9502

EMAIL: treatdistadmin@mountvernonohio.org

I CERTIFY UNDER PENALTY OF LAW THAT I HAVE PERSONALLY EXAMINED AND AM FAMILIAR WITH THE INFORMATION IN THIS REPORT AND ALL ATTACHMENTS. BASED ON MY INQUIRY OF THOSE PERSONS IMMEDIATELY RESPONSIBLE FOR OBTAINING THE INFORMATION CONTAINED IN THE REPORT, I BELIEVE THAT THE INFORMATION IS TRUE, ACCURATE, AND COMPLETE.


Signature of Official


Date

Interim Administrator
Title

Enter narrative
analysis of WIB
patterns by location,
frequency and cause.

426 Main Line had obstruction that was manually removed.
425 Main line blockage.
417 Severe weather all sewers running at capacity.
410 Main line plugged, main was jetted.
418 two occurrences plugged line due to collapsed line, several sections of
main replaced.
408 Main was plugged.
440 Section of pipe failed, dug and replaced.

