



Sanitary Sewer Overflow Annual Report

Division of Surface Water

Date: 9 March 2015
Facility name: Mount Vernon Wastewater Treatment Plant
Ohio NPDES permit no.: 4PD00100*MD
Period covered by report: 1 January through 31 December 2015

Contact person

Name: Mathias G Orndorf
Title: Director of Public Utilities
Mailing address: 3 Cougar Drive Mount Vernon, Ohio 43050
Telephone: (740)393 - 9584
Email: treatdistadmin@mountvernonohio.org

Certification:

I certify under penalty of law that I have personally examined and am familiar with the information in this report and all attachments. Based on my inquiry of those persons immediately for obtaining the information contained in the report, I believe that the information is true, accurate, and complete.

Name Mathias G Orndorf
(typed):

Title: Director of Public Utilities

Signature:

Mathias G Orndorf

Date:

9 MARCH 2016

SSO Annual Report Table 2: SSO Event Information

Ohio NPDES Permit No.: 4PD00100*MD

Date ^A	Identification No. ^B	Receiving Water ^C	Volume ^D
9 April 2015	301	Kokosing River	?
17 June 2015	302	Tributary to the Kokosing River	0.35
20-21 June 2015	302	Tributary to the Kokosing River	0.35
17 December 2015	303	None	0.0001

- A. Enter date as "MM/DD/YY". Enter "Various" to summarize overflows of less than 1000 gallons from an SSO location
- B. Enter the unique identification assigned in Table 1.
- C. Enter name of receiving water. If an SSO enters a storm sewer, enter "SS to (name of receiving water)." If an SSO does not reach a receiving water, enter "None".
- D. Enter estimate of volume in MG (million gallons). Enter estimate of total volume if summarizing data.

Use additional pages as needed.

SSO Annual Report Table 3: Water in Basement Occurrences		Ohio NPDES Permit No.: 4PD00100*MD
Sewershed ^A	WIB Occurrences ^B	Causes ^C
412	1	B,D
417	4	B,D
Total Occurrences	5	

A. A sewershed is a specific geographic area, such as a city block or a subdivision, that drains to a common outlet.
 B. Enter the total number of water in basement occurrences report for the sewershed.
 C. Enter all causes that apply: W = extreme weather; E = equipment failure; P = power failure; D = debris in line; R = roots; G = grease; B = other blockages; L = Line deterioration; V = vandalism; O = other, provide details.

Use additional pages as needed.

Enter narrative analysis of WIB patterns by location, frequency and cause.

412- 4 April 2015,507 Coshocton Ave. 1645 hrs. Back up from surcharged, blocked line. Resident filed a claim.

417-23 June 2015, 710,703 Coshocton Ave. and 3,4 Hilltop Drive 1230hrs. Line blockage caused surcharge to residents.