



Sanitary Sewer Overflow Annual Report Division of Surface Water

Date: 02/21/2019

Facility Name: Mount Vernon WWTP

Ohio NPDES Permit Number: 4PD00100*MD

Period Covered by Report: 01/01/2018 - 12/31/2018

Contact Person

Name: Mathias Orndorf

Title: Director of Public Utilities

Mailing Address: 3 Cougar Drive

City: Mount Vernon

State: OH

Zip Code: 43050

Country: USA

Sanitary Sewer Overflows Spreadsheet(attachment) : 2018 in progress.xlsm

Water In Basement Occurrences Spreadsheet(attachment) : WIBOccurrences2018.xlsm

Narrative analysis of WIB patterns by location, frequency and cause: *In July a construction company had lost a laser level when installing new sewer pipe. Later in August the laser level became lodged in the manhole at square, thusly causing a blockage. The first customer assumed it was his plumbing that was an issue so back up continued to grow and effect numerous customers. The construction companies insurance was informed and is supposed to be taking care of costs. To exacerbate the problem the State was paving the area so manholes were hard to locate.*

Additional Attachments :

<i>I certify under penalty of law that I have personally examined and am familiar with the information in this report and all attachments. Based on my inquiry of those persons immediately responsible for obtaining the information contained in the report, I believe that the information is true, accurate, and complete.</i>	
Name: Mathias G Orndorf	Title: Director of Public Utilities
Signature(Electronically submitted by): Mathias G Orndorf (User ID: morndorf)	Submission Date: 02/21/2019

SSO Annual Report - Data Entry Spreadsheet

Permit Number

4PDD00100*MD

Facility Name

City of Mount Vernon Waste Water Plant

Reporting Period

From: 1/1/2018

To:

12/31/2018

Table 2: SSO Event Information

Event Date	Identification Number	Receiving Water	Volume (millions of gallons)
2/16/2018	301	Tributary of Kokosing River	0.1898
2/16/2018	302	None	0.000001
2/25/2018	301	Tributary of Kokosing River	0.1062
2/25/2018	302	None	0.000001
4/4/2018	302	None	0.000001
8/28/2018	303	SS to Kokosing	0.01152
12/15/2018	304	Tributary of Kokosing River	0.001

SSO Annual Report - Data Entry Spreadsheet

Permit Number

4PD00100*MD

Facility Name

City of Mount Vernon Waste Water Plant

Reporting Period

From:

1/1/2018

To:

12/31/2018

Table 1: SSO Identification

Identification Number	Receiving Water	Location Description	Date Eliminated
301	Tributary of Kokosing River	Clinton Rd L.S. N40.245929-W82.294120	
302	None	Manhole KO1A N40.37799-W82.46897	
303	SS to Kokosing	ADMB-002974R N40.39891016-W82.46035524	
304	Tributary of Kokosing River	N40.220684 W82.282859	12/20/2018

Other Cause Description
Laser Level blocked sewer for about a block of customers, event lasted for days and customers were referred to construction company's insurance.